
 NB: DENOTES VERTICAL FIRE BREAK AT PARTY WALL. INTUMESCENT STRIP FIRE BARRIER TO BE INSTALLED BEHIND THE INSULANT.

 NB: DENOTES HORIZONTAL FIRE BREAK AT FLOOR LEVEL WITH INTUMESCENT STRIPS BEHIND THE INSULANT INSTALLED

- 6 fixings required through each board, three fixings through the board centre line and 3 half fixings down each side

Secondary WBS stainless steel fixing to be installed through the scrim coat and mesh at 1 per m²

Epsitec rails to be installed at 600mm centres

Rails to be fixed each side at 300mm centres

In areas where the board is not fully supported, horizontal cavity spacer tracks to be installed where appropriate

WBS approved sheathing boards to be fixed and jointed to manufacturers instructions

drawing. **Fixing arrangement
(above 2 storeys)**

date. April 2009

revision. -

drawn by. JR

scale. nts

drawing no. **EPSITEC-EWI-02B**

drawing set. 09



1 Kid Glove Road, Golborne Enterprise Park,
Golborne, Greater Manchester, WA3 3GS
Tel: 01942 717100 Fax: 01942 717101
Web: www.wbs-ltd.co.uk
E-mail: technical@wbs-ltd.co.uk