


Source: **own catalogue - Own**  
Component: **Typical Woolaway Houses**

OUTSIDE

INSIDE



Assignment: External wall

	Manufacturer	Name	Thickness [m], number	Lambda [W/(mK)]	Q	R [m²K/W]
		Rse				0.04
<input checked="" type="checkbox"/>	1	WBS	0.008	0.556	<b>E</b>	0.01
<input checked="" type="checkbox"/>	2	WBS	0.060	0.020	<b>E</b>	3.00
		Fixings	8/m²	0.500	<b>D</b>	-
		Air gaps	Level 1: dU" = 0.01 W/(m²K)			
<input checked="" type="checkbox"/>	3	Own catalogue	0.050	0.833	<b>E</b>	0.06
<input checked="" type="checkbox"/>	4	Own catalogue	0.050	0.278	<b>E</b>	0.18
<input checked="" type="checkbox"/>	5	Own catalogue	0.050	0.833	<b>E</b>	0.06
<input checked="" type="checkbox"/>	6	Own catalogue	0.013	0.382	<b>E</b>	0.03
		Rsi				0.13
						<b>0.231</b>

$$R_T = R_{si} + \sum R_i + R_{se} = 3.52 \text{ m}^2\text{K/W}$$

Correction to U-value for	according to	delta U [W/(m²K)]
Mechanical fasteners	BS EN ISO 6946 Annex D	0.000
Air gaps	BS EN ISO 6946 Annex D	0.007
<b>Air gaps and fixings corrections need not be applied, as their total effect is less than 3% (Annex D BS 6946:1996).</b>		
		0.000

$$U = 1/R_T + \sum \Delta U = 0.28 \text{ W/(m}^2\text{K)}$$

- Q .. The physical values of the building materials has been graded by their level of quality. These 5 levels are the following
- A** .. A: Data is entered and validated by the manufacturer or supplier. Data is continuously tested by 3rd party.
  - B** .. B: Data is entered and validated by the manufacturer or supplier. Data is certified by 3rd party
  - C** .. C: Data is entered and validated by the manufacturer or supplier.
  - D** .. D: Information is entered by BuildDesk without special agreement with the manufacturer, supplier or others.
  - E** .. E: Information is entered by the user of the BuildDesk software without special agreement with the manufacturer, supplier or others.

$$U_{\max} = \boxed{0.35 \text{ W/(m}^2\text{K)}}$$

$$U = \boxed{0.28 \text{ W/(m}^2\text{K)}}$$

$$R_T = \boxed{3.52 \text{ m}^2\text{K/W}}$$

Source of U<sub>max</sub> value: England, Wales: Approved Document L1A (2006), Table 2 - New Build Dwellings